

No. 707 /T/ 2016

Office of the
Assistant Engineer Grade-I
Public Works Sub-Division (Rural)
Nagpur
ruralnagpur.de@mahapwd.com
Dated : 25 / 05 / 2016

✓ To,
Executive Engineer,
Public Works Division No. II,
Nagpur


Subject : Building safety Certificate.

Reference : Principal, Jain International School, Nagpur Letter No. JIS/NGP/LET/05.16/129
dt. 25th May, 2016

With reference to letter under reference it is submitted that the work was executed by
Pvt. Architect with his design.


The Building safety certificate issued by the Ar. Sachin Kothari may be considered
for further purpose.

Encl: As above.



Assistant Engineer
Public Works Sub-Division (Rural)
Nagpur

Copy to – Shri S.S. Khobragade, A.E.-II for information & necessary action

साध्यक अभियंता (श्रेणी - १)
स्वा. र्त. उपविभाग (ग्रामिण)
नागपूर


Principal
The Jain International School, Nagpur
CBSE Affiliation No. 1130149


Manager
The Jain International School, Nagpur
CBSE Affiliation No. 1130149



- PLANNER
- ARCHITECT
- CAMPUS DESIGNER
- VASTU CONSULTANT

15/2, Priyadarshini Society, Behind R.T.O.,
Civil Lines, Nagpur-01 (MH), Telfax: 0712 - 2538880
Cell. 9373338880, 9372338880, 9372308880

ARCHITECTS

CERTIFICATE

- Building is supported on structure with reinforced concrete column, beams and slab which is enough to take the load of existing structure, fix of the beams and reinforcement provided is enough to take the load of the existing structure.
- I hereby certify that building is structurally stable with above structural parameters.
- The above certificate is based on assumption that reinforcement is provided as per structural drawing provided. It is assumed that concrete mix used is M-20 for columns, beams & slabs as per IS-456-2000

Date - 18/1/2016
Place - Nagpur

Ar. Sachin Kothari


15/2, Priyadarshini Society,
Civil Lines, Nagpur-01 (MH),
Telfax: 0712 - 2538880
Cell. 9373338880, 9372338880, 9372308880


Principal

The Jain International School, Nagpur
CBSE Affiliation No. 1130149

Manager

The Jain International School, Nagpur
CBSE Affiliation No. 1130149





ARCHITECTS

- PLANNER
- ARCHITECT
- CAMPUS DESIGNER
- VASTU CONSULTANT

15/2, Priyadarshini Society, Behind R.T.O.,
Civil Lines, Nagpur-01 (MH), Telfax: 0712 - 2538880
Cell: 9373338880, 9372338880, 9372308880

- **PROJECT** : Structural Stability of the Building
- **LOCATION** : M/s The Jain International school
Behind Assaram Bapu Ashram
Village - fetri, katol raod, Nagpur.
- **DRAWING REFERED** : APPROVED PLAN STRUCTURAL DRAWING
- **BUILDING DETAILS** :
BUILDING STRUCTURE : Frame Structure With Columns & Beams
Supported on RCC Foundation.

Floor areas

- (A) Junior school : Ground Floor : 24920.00 sq.ft.
First Floor : 25170.00 sq.ft.
- (B) Middle school : Ground Floor : 27270.00 sq.ft.
First floor : 21430.00 sq.ft.
Second floor : 19980.00 sq.ft.

Date – 18/1/2016

Place – Nagpur

Ar. Sachin Kothari

Principal


The Jain International School, Nagpur
CBSE Affiliation No.1130149

Manager

The Jain International School, Nagpur
CBSE Affiliation No.1130149

15/2, Priyadarshini Society,
Civil Lines, Nagpur-01 (MH), Telfax: 0712 - 2538880
Cell: 9373338880, 9372338880, 9372308880





- PLANNER
- ARCHITECT
- CAMPUS DESIGNER
- VASTU CONSULTANT

15/2, Priyadarshini Society, Behind R.T.O.,
Civil Lines, Nagpur-01 (MH), Telfax: 0712 - 2538880
Cell 9373338880, 9372338880, 9372308880

ARCHITECTS

Height	: 40 FT from ground level
Beam spacing	: 10 FT (minimum)
Main beam B (size)	: 12" width 2'6" height
Side beam	: 9" width 2'6" height
Cantilever beam	: 9" width 2'6" height
Slab thickness	: 5" & 6"
Slab Reinforcement	: 10-12 mm Dia 150 mm C/C On both side
Wall thickness	: 9"
Plastering (inside)	: Neroo finished
Plastering (outside)	: Neroo finished
Foundation	: RCC footing (1.50 m depth)
Column	: 32 mm dia. To 16 mm dia.

Date – 18/1/2016
Place – Nagpur

Ar. Sachin Kothari

Sachin Kothari

Abdjalat
Principal

The Jain International School, Nagpur
CBSE Affiliation No. 1130149

Manager

The Jain International School, Nagpur
CBSE Affiliation No. 1130149

